


515

LIBRARY
STATE OF HAWAII
DEPARTMENT OF BUSINESS AND
ECONOMIC DEVELOPMENT & TOURISM
P.O. Box 2359
Honolulu, Hawaii 96804



HAWAII DEEP WATER CABLE PROGRAM

PHASE II-D

TASK 5

REVISED BASIC DESIGN CRITERIA

DATA BOOK

TK3351
H35
PIID
T5
1988
c.1

Department of Business and Economic Development

HAWAII DEEP WATER CABLE PROGRAM

PHASE II-D

TASK 5

REVISED BASIC DESIGN CRITERIA
DATA BOOK

Prepared by

G. Krasnick and J. Mansur
of Parsons Hawaii

for

Hawaiian Electric Company, Inc.

and the

State of Hawaii

Department of Business and Economic Development

AUGUST 1988

TABLE OF CONTENTS

PART 1	INTRODUCTION
PART 2	ENVIRONMENTAL AND ROUTE FACTORS
PART 3	ELECTRICAL GRID SYSTEM
PART 4	CABLE SUBSYSTEM
PART 5	CABLE VESSEL SUBSYSTEM
PART 6	CABLE HANDLING EQUIPMENT SUBSYSTEM
PART 7	AT-SEA TEST EQUIPMENT AND ACTIVITIES
PART 8	BASIC DESIGN CRITERIA REFERENCES

LIST OF FIGURES

NUMBER	TITLE	PAGE
2-1	Cumulative percent frequency of exceedance of wind speed from NWS Upolu Station (March 1984 - February 1986)	2-2
2-2	Annual and seasonal percent frequency of occurrence distributions of wind speed from the NWS Upolu Station	2-2
2-3	Comparison of monthly % frequency of time sustained winds \leq 20 knots from NWS Upolu and Upolu 38 Stations	2-3
2-4	Monthly % frequency of time waves \leq 6 feet in the Alenuihaha Channel	2-3
2-5	Estimated peak tidal currents along the proposed cable route, Alenuihaha Channel	2-7
2-6	Seasonal variation of winds, waves and currents in the Alenuihaha Channel offshore Upolu Point	2-10
2-7	Preferred route from Hawaii to Oahu	2-12
2-8	Potential routes across the Alenuihaha Channel identified in the First Bottom Roughness Survey	2-14
2-9	Cable path across the Alenuihaha Channel as defined by the Second Bottom Roughness Survey	2-15
2-10	Final recommended cable path for the Maui Slope with critical widths indicated	2-16
2-11	Final recommended cable path for the Kohala slope with critical widths and tensions indicated	2-17
2-12	Final recommended submarine route from Maui to Oahu	2-21
2-13	Potential overland corridors on Hawaii	2-25
2-14	Potential overland corridors on Maui	2-26
2-15	Potential overland corridors on Oahu	2-27

FIGURES - Continued

NUMBER	TITLE	PAGE
3-1	Conceptual schedule for HDWC/HVDC project	3-8
3-2	Cable converter staging	3-9
4-1	Cross-section of self-contained oil-filled cable	4-3
5-1	Cable tension vs. deployment depth at various sea states	5-2
5-2	Environmental loading during cable laying	5-3
5-3	Design barge forces	5-4
6-1	Conceptual drawing of the major cable handling machinery for the HDWC Program	6-2
7-1	Cross-section of surrogate cable	7-2
7-2	<u>M/V Flexservice 3</u>	7-5
7-3	Deployment reel for surrogate cable	7-7
7-4	TR 23 winch	7-8
7-5	TR 25 winch	7-9
7-6	TR 7 winch	7-10
7-7	50-ton tensioner	7-11
7-8	Overboarding sheave	7-12
7-9	Inputs/outputs to Integrated Control System	7-14
7-10	Basic Control System Loop	7-15
7-11	Ships and Components of the HDWC At-Sea Test	7-17

LIST OF TABLES

NUMBER	TITLE	PAGE
2-1	Alenuihaha operational design waves (Exceeded 10% of the time)	2-4
2-2	Estimated peak tidal currents along the proposed cable route, Alenuihaha Channel	2-6
2-3	Operational wind-induced design currents for tradewind and Kona wind conditions	2-8
2-4	Estimated peak operational eddy currents along the proposed cable route, Alenuihaha Channel	2-9
2-5	Distance and depth characteristics of preferred route	2-11
2-6	Approximate distance with depth ranges for the submarine route	2-22
4-1	Selected basic design characteristics of cable design No. 116	4-1
4-2	Cable dimensions (by layer)	4-5
5-1	Input data for vessel Tv graph (Figure 2-19)	5-2
5-2	Summary of Tension Dynamic Amplification Factors	5-5
7-1	Technical data on surrogate cable	7-1
7-2	Technical data on <u>Flexservice 3</u>	7-3

PART 1

INTRODUCTION

This Revised Basic Design Criteria Data Book supercedes the 1985, original version. Its purpose and structure have not changed, but technical data have been updated and a new section on the At-Sea Test added. The book remains a reference manual that identifies the major, basic design elements and criteria to which the cable, cable vessel and cable handling equipment subsystems must operate. It is NOT a final design criteria manual, and is NOT meant to replace detailed technical reports, drawings or specifications. It is intended to be used as a quick reference document for the subsystem listed above.

PART 2

ENVIRONMENTAL AND ROUTE FACTORS

Environmental Factors

The design environmental criteria/conditions that apply to the Alenuihaha Channel are as listed below. All equipment and operations are to function under these conditions.

Winds

The following information was generated by Haraguchi (Pacific Weather, 1986) from field measurements and literature comparisons.

Tradewinds are persistent during the summer months but are reduced to near 50% during the winter months. The average monthly wind speeds are strongest for the summer months and weakest for winter and fall months. However, the strongest daily tradewinds occur during winter and spring months when very strong high pressure cells pass from the west to east north of the islands. Figures 2-1 and 2-2 show the seasonal variations of the winds from the NWS Upolu Station based on two years of data.

The NWS Upolu Station is automatically queried every hour and the 1-minute sustained wind speed and peak gust data are available for operational use at the Honolulu office of the NWS. Unfortunately, the wind speed from this station has significant error in characterizing the channel winds because of the sensor location and land effects. Thus, another Upolu Point wind station (Upolu 38) was established for about one year in a more exposed location. Average monthly wind speeds from Upolu 38 are significantly higher than the NWS Upolu winds. Figure 2-3 compares the monthly % frequency of time in which the sustained winds are ≤ 20 knots for the NEW Upolu and Upolu 38 stations.

From Haraguchi's data, an operational design tradewind speed of 30 knots is established. A sustained tradewind speed of 30 knots is expected to be exceeded less than 5% of the time during a typical year. An operational design Kona wind speed of 25 knots is established. Southerly to westerly winds occurred only about 16% of the time during the 2-year data period. Of the times when Kona winds occurred, a sustained speed of ≥ 25 knots occurred less than 5% of the time.




Figure 2-1 Cumulative percent frequency of exceedence of wind speed from NWS Upolu Station (March 1984–February 1986)




Figure 2-2 Annual and seasonal percent frequency of occurrence distributions of wind speed from the NWS Upolu Station




Figure 2-3 Comparison of monthly % frequency of time sustained winds ≤ 20 knots from NWS Upolu and Upolu 38 Stations




Figure 2-4 Monthly % frequency of time waves <6 feet in the Alenuihaha

Waves

Operational wave criteria are summarized in Noda (1986) from field measurements and literature comparisons.

The wave climate in Hawaiian waters is characterized by two primary seasons: summer and winter. The summer wave climate is dominated by the strong northeasterly trade-wind-generated waves as well as southern swell generated by distant winter storms in the southern hemisphere. In the Alenuihaha Channel, the high-energy tradewind waves predominate over the low energy southern swell. However, these two wave types can occur simultaneously. The winter wave climate is characterized by a weakening of the tradewinds and the occurrence of infrequent southwesterly "Kona" storm waves as well as frequent northwesterly swell generated by winter storms in the North Pacific or by mid-latitude low pressure systems. The Alenuihaha Channel is somewhat sheltered from the northwesterly swell by the island of Maui, but is directly exposed to southwesterly waves.

In order to determine which month(s) are most favorable for deployment operations, Figure 2-4 shows the cumulative percentage of time that significant wave heights are ≤ 6 feet on a monthly basis. From this figure, it appears that the summer months of June through September are the most favorable in terms of significant wave heights being less than 6 feet about 80% or more of the time.

Since the wave climate varies seasonally, the operational design wave will be expected to vary depending on the time of year. The operational design wave is defined here as the significant wave height that is expected to be exceeded about 10% of the time during any given month. The design period is given as the range of average wave periods associated with the given design wave height. Table 2-1 lists the monthly operational design wave conditions.

Table 2-1

ALENUIHAHA OPERATIONAL DESIGN WAVES (EXCEEDED 10% OF THE TIME)

Month	H_s (ft)	T (sec)
Jan	8.6	4-10
Feb	9.4	6-10
Mar	11.1	6-10
Apr	10.0	4-8
May	7.8	4-8
Jun	6.1	4-6
Jul	6.6	4-6
Aug	6.8	4-6
Sep	6.2	4-8
Oct	7.6	4-10
Nov	8.8	4-8
Dec	9.8	4-8

The significant wave height (H_s) is defined as the average of the highest 1/3 of all wave heights. Thus, wave heights higher than the significant wave height occur simultaneously within the wave spectrum. Assuming a Rayleigh distribution of heights, the highest one percent of all waves is $H_L = 1.67H_s$. This would mean, for example, that for a given sea state described by a significant wave height of 6 feet, the range of wave heights between H_s and H_L is 6-10 feet.

Currents

Coastal currents in the vicinity are typically comprised of the following components:

- Tidal currents
- Wind-driven currents
- Eddy currents
- Background oceanic currents

The relative magnitudes of these components vary depending on the particular location, distance from shore, and also vertically with depth.

Available current data in the Alenuihaha Channel indicate that the currents are primarily driven by the tides and winds, and are influenced by eddy currents. Eddy currents, while being a predominant component in waters west of Hawaii, are not as dominant a feature within the channel itself. It is postulated that strong winds blowing through the channel may be the mechanism for eddy formation. However, fully developed eddies do not "live" within the confines of the channel, although they may influence the near-surface currents within the channel.

Currents in the Alenuihaha Channel below about 300-400 meter depth are primarily driven by the tides. These tidal currents rotate in direction, with peak currents occurring towards the ENE and WSW. The period between peak currents is between 6 and 12 hours corresponding to the high and low tide cycles of the semi-diurnal and diurnal tidal constituents. Currents in the upper 300-400 meter depth are influenced by wind-driven and eddy currents. These currents are superimposed on the tidal currents.

The tidal currents within the channel are influenced by bathymetry, and hence vary depending on location. For the proposed cable route, which crosses the channel nearly perpendicular to the bottom contours, the peak tidal currents are expected to flow nearly perpendicular to the cable axis. Based on correlations between the current meter data and the XCP vertical profiles, Table 2-2 gives the estimated peak tidal currents along the proposed cable route. These currents are provided as a function of nominal bottom depth along the cable

route. Largest tidal currents occur in shallower water depths at the edges of the channel and on the steep Kohala slope in mid-channel. An interpolation of peak tidal currents along the proposed cable route is shown in Figure 2-5.

Table 2-2

ESTIMATED PEAK TIDAL CURRENTS ALONG THE
PROPOSED CABLE ROUTE, ALENUIHAHA CHANNEL


Location	Bottom Depth (m)	Speed (cm/sec)
Offshore Upolu Pt	170	46
	500	43
	800	39
Top of Kohala Slope	900	37
	1000	39
	1600	46
Bottom of Kohala Slope	1900	41
	2000	36
	1500	45
Maui Slope	900	53
	200	55

Note: Peak tidal currents can flow towards ENE or WSW, generally perpendicular to contours. Typical direction is $70^{\circ}T/250^{\circ}T$ along cable path.

Mean background oceanic currents are also evident in the channel. These currents are superposed on the tidal currents and can occur in either an east-northeasterly or westerly direction, with an apparent period of oscillation of about 20-25 days. A background oceanic current of 10 cm/sec is assumed for the operational current criteria.

Currents in the Alenuihaha Channel in the upper 200-300 meters are influenced by wind-driven and eddy currents. Wind-driven currents are on the order of 2% of the wind speed near the surface, decreasing exponentially with depth. The direction of the surface current is 45° cum sole from the direction of the wind, with the direction deflected clockwise with depth so that at a depth $z = D$, the direction is opposite to the surface current. At this depth D , which is about 200 meters for a wind speed of 30 knots, the current speed is only about 4% of the surface current speed. The wind-induced operational currents are given in Table 2-3 for strong tradewind and Kona wind conditions.

For the purpose of defining a design operational eddy profile, we assumed a mean eddy current uniform in speed and direction within the upper 50 meters, decreasing linearly to zero at 200 meter depth. The speed of the near-surface eddy current decreases from a maximum of 70 cm/sec on the Hawaii side of the channel to 20 cm/sec on the Maui side. Table 2-4 lists the estimated peak operational eddy currents along the proposed cable route.



PROPOSED CABLE ROUTE ACROSS ALENUIHAHA CHANNEL (Approx. 1"=20,000')

- (1) XCP locations are approximate and vary somewhat with each drop due to method of positioning.
- (2) A-1, A-2 = Aanderaa near-bottom stations, SD = Sea Data near-surface station

Figure 2-5 Estimated peak tidal currents along the proposed cable route, Alenuihaha Channel

Table 2-3

OPERATIONAL WIND-INDUCED DESIGN CURRENTS
FOR TRADEWIND AND KONA WIND CONDITIONS

TRADEWIND CONDITIONS

Sustained wind speed 30 knots

Wind direction from 70°T

Depth (m)	Speed (cm/sec)	Direction (°T)
0	33.3	295
25	22.4	318
50	15.1	340
75	10.2	3
100	6.9	25
125	4.6	48
150	3.1	71
175	2.1	93
200	1.4	116

KONA WIND CONDITIONS

Sustained wind speed 25 knots

Wind direction from 225°T

Depth (m)	Speed (cm/sec)	Direction (°T)
0	27.7	90
25	17.3	117
50	10.8	144
75	6.7	171
100	4.2	198
125	2.6	226
150	1.6	253
175	1.0	280
200	0.6	307

Table 2-4

**ESTIMATED PEAK OPERATIONAL EDDY CURRENTS
ALONG THE PROPOSED CABLE ROUTE, ALENUIHAHA
CHANNEL**

Location	Bottom Depth (m)	Speed (cm/sec)	Direction (°T)
Offshore Upolu Pt	170	70	45
	500	65	50
	800	54	50
Top of Kohala Slope	900	45	50
	1000	44	50
	1600	40	50
Bottom of Kohala Slope	1900	38	60
	2000	34	80
	1500	25	115
Maui Slope	900	20	125
	200	16	130

Note: Eddy current given is the mean current within upper 50 meters. The eddy current is assumed to decrease linearly to zero at 200 meter depth.

Summary of Environmental Factors

Winds and waves vary seasonally while currents do not show a significant seasonal trend, as generally depicted in Figure 2-6. In this figure, significant wave heights <6 feet are expected to occur 81% of the time during the summer months, decreasing to 66% of the time during the winter months and 36% of the time during the spring months. Wind speeds <20 knots (measured at the NWS Upolu Station) are expected to occur about 97-99% of the time during the summer and fall months, decreasing to less than 90% of the time during the spring. Near-surface current speeds <50 cm/sec are expected to occur about 70% of the time throughout the year. From this data, the least favorable time of year for deployment operations is in the spring (March-April). Tradewinds are gusty and high wave conditions result from the combination of tradewind generated seas and late winter as well as early summer swell. The most favorable time of year is during the summer months when typical tradewind waves predominate.




Figure 2-6 Seasonal variation of winds, waves and currents in the Alenuihaha Channel offshore Upolu Point

Route Factors

Worst case thermal bottom conditions are as follows (H1G, 1983).

MAXIMUM AMBIENT (degrees C)	COVER DEPTH (m)	THERMAL RESISTIVITY (c-cm/W)
25 (77 degrees F)	3 (9.8 ft)	150
14 (57 degrees F)	10 (32.8 ft)	150
3 (37 degrees F)	100 (320.8 ft)	150

Sea bottom conditions around the Hawaiian Islands are unstable due to earthquakes, landslides, turbidity flows, volcanoes, etc.

Figure 2-7 is a composite drawing of a possible route from Hawaii to Oahu. Table 2-5 summarizes distances along segments of this route. The following subsections excerpt results of the most significant seafloor and terrestrial surveys which contributed to definition of this possible route.

Table 2-5

DISTANCE AND DEPTH CHARACTERISTICS OF PREFERRED ROUTE, April, 86

Hawaii to Maui to Oahu

FROM	TO	SEGMENT	OH/SUB	LENGTH	
				KM	MI
Puna	Keaau	1H	OH	23	14
Keaau	Kawaihae	2H	OH	129	80
Kawaihae	Mahukona	3H	OH	23	14
Mahukona	Alenuihaha	4H	SUB	32	20
Alenuihaha	Alenuihaha	1A	SUB	19	12
Alenuihaha	Huakini Bay	1M	SUB	16	10
Huakini Bay	Ahihi Bay	2M	OH	32	20
Ahihi Bay	Waimanalo	3M	SUB	154	96
Waimanalo	Aniani	10	OH	5	3
TOTAL OVERHEAD				212	131
TOTAL SUBMARINE				221	138

PERCENTAGE SUBMARINE = 51%

LONGEST SUBMARINE RUN = 154 km




FIGURE 2-7
PREFERRED ROUTE
HDWC PROGRAM


REVISED - AUGUST 1987

Submarine Route Segments

The general nature of the bottom of the Alenuihaha Channel was characterized in several University of Hawaii surveys using side-scan sonar and bathymetric mapping. These studies served to identify the roughest areas of the cable route which were later studied in greater detail in the First Bottom Roughness Survey (MOE, EKNA and HIG, 1986). Figure 2-8 summarizes potential routes identified in that work. This survey found two very hazardous areas, one on the Kohala side of the channel and one on the Maui side of the channel, which necessitated an even more detailed survey, the Second bottom Roughness Survey (MOE and Scripps, 1987). Figure 2-9 is the final route across the channel recommended in that report. Figures 2-10 and 2-11 are more detailed drawings of the critical areas of the Maui and Kohala slopes, respectively. Key conclusions and recommendations of the Second Bottom Roughness Survey are as follows.

ROUTE LOCATION AND CABLE LAYING

- o A continuous path, but not an easy one, has been found that may be adequate for a commercial cable across the Alenuihaha Channel.
- o The path width, required bottom cable laying tensions and the bottom roughness have been defined for this selected cable route.
- o Precision cable laying will be required on both the Maui and the Kohala sides of the channel, but more so on the Maui side for accuracy, more so on the Kohala side for tension.
- o The bathymetry along a survey track has an accuracy of 10 m and the multiple surveys agree within 5 m.
- o Key obstacles are located to a 10 m accuracy, possibly better.
- o The positioning and bathymetry is adequate for laying the test cable except for possibly tying in the key obstacles into the cable laying navigation grid just prior to the cable lay.
- o The bottom of the recommended cable path is primarily smooth, spans are not a problem and low cable laying tension is not required except at the top of the Kohala slope where a low tension of 1000 kg is recommended. All other locations along the path have a recommended cable tension of 3000 kg or less.
- o As concluded in the first cruise, it is better to lay the cable at a low tension rather than a high one to avoid unacceptable spans.






Figure 2-9 Cable Path across Alenuihaha Channel




Figure 2-10 Final Recommended Cable Path for the Maui Slope with Critical Widths Indicated




Figure 2-11 Final Recommended Cable Path for the Kohala Slope With Critical Widths & Cable Tensions Indicated. Hatched Path Area Requires Low Cable Tension at 1000 Kg.

MAUI SLOPE

- o The Maui slope region above the saddle area in the Alenuihaha Channel is a complex series of terraced escarpments through which it was difficult to wind a continuous path.
- o As a result of the excellent agreement between sidescan, precision bathymetry and Sea MARC, the surveyed portion of the Maui slope is now known well and an overall map of this region has been prepared.
- o Major obstacles on the Maui slope occurred at the 1000 m level, 1200 m level and 1500 m level.
- o The bottom of the recommended path is smooth in all regions and cables can be laid at a tension up to 5000 kg without unacceptable spans. 3000 kg or lower tensions are recommended, if possible.
- o The path width is 400 m and wider in most locations with the exception of a narrow portion at 900 m depth which is 170 wide and the narrowest portion at 1200 m depth which is 80 m wide.
- o The recommended Maui path is not straight with the sharpest bend occurring at 1000 m depth at a 500 m to 700 m turning radius.
- o The shallowest portion of the recommended path is 550 m; the survey did not extend inshore of this point.
- o Much of the survey time was spent searching for alternate cable paths and extending the search far to the east and the west of the originally planned area. Orienting the Sea MARC data relative to the Deep Tow tracks during the post-cruise analysis indicated that there are potential routes both further to the east and the west of the actual search area and one possible route short-cutting the sharp bend radius at 1000 m in the proposed cable path. Neither of these potential routes can be confirmed on the basis of the present data.
- o For the search area covered, it is unlikely that there is an alternate acceptable path in the 1200 m to 1500 m region.

KOHALA SLOPE

- o The Kohala side of the channel is more easily defined with one single steep slope from 930 m to 1930 m and with several lava flows at the top of the slope.
- o The lava flows at the top of the slope and the considerable roughness at the top edge of the slope are the major restrictions to a cable path.
- o The lower portions of the Kohala slope were predominantly smooth.
- o A path cannot be found across the top of slope that is free of unacceptable spans for a cable laid at 3000 kg or greater.
- o The only means found of crossing the upper portion of the Kohala slope without an unacceptable cable span is to lay the cable at a low tension of 1000 kg or less.
- o The acceptable width of the Kohala path at the top of the slope is difficult to determine by sidescan since it is only a qualitative tool and the area has some roughness. The final selected width of 200 m encompasses the region traversed by 5 separate survey tracks.
- o Alternate paths along the Kohala slope were considered but not found to be acceptable. An attempt was made at a path far to the east but that proved unacceptable. This survey did not prove, however, that an acceptable path does not exist in this region.

CHANNEL BOTTOM

- o The bottom of the channel is predominantly smooth, sediment covered on the Kohala side and with some small scale rubble on the Maui side.
- o A wide, fairly straight path has been found across the channel bottom.

RECOMMENDATIONS

- o Although the majority of the cable path has a smooth bottom and no unacceptable spans are expected for cable tensions up to 5000 kg, lower tensions of 3000 kg or less are recommended, if operationally feasible, in order to further minimize the probability of unacceptable spans.
- o An additional survey with a submersible or ROV in the narrow regions on both sides of the channel would help in further understanding the cable path for the HDWC program. This would particularly be valuable at the top of the Kohala slope and at the 1200 m narrow region on the Maui slope.
- o For precise cable laying, it will be necessary to tie in the position of the major constraining obstacles into the cable laying navigation grid prior to laying the cable.
- o Because of the extreme topographic variations, particularly on the Kohala slope, great care will be necessary in the placement of the bottom transponders in any future acoustic navigation grid.
- o Before laying the commercial cable, further surveys of the route should be made concentrating along the selected path & insuring that all areas are 100% covered by sidescan and all questionable targets investigated with a BRS/Deep Tow fine resolution bathymetry system.

The remainder of the submarine route was surveyed by Seafloor Surveys International. The final route between Maui and Oahu indicated by their survey is shown in Figure 2-12. The data indicated that there were areas where critical cable spans occurred off Central Maui, west of Lahaina, north of Lanai, south of West Molokai, and across a submarine canyon off Makapuu, Oahu. Some of the critical spans, for example those off Lahaina, were only present at higher cable tensions and thus would not constitute a barrier to cable installation in these relatively shallow waters.

Special efforts were made to find routes around the steep areas. The potential cable spans off Central Maui, Panels 24 and 27 were due to very large blocks located at the base of the 100 meter reef. Several crossings of the base of this reef were made, and the blocks were found to be a common feature on all the crossings. With considerable searching, a route through the blocks could probably be found, but it seemed more logical to find an alternate route in shallower water where the bottom was expected to be smoother. This alternate route proved quite favorable, and became the preferred route. The calculated cable spans north of Lanai and off Makapuu are located in areas where the route crossed steep-sided submarine canyons. Acceptable routes around the heads of these canyons were found and surveyed.




FIGURE 2-12 FINAL RECOMMENDED SUBMARINE ROUTE FROM MAUI TO OAHU

Bathymetry

The submarine route has been divided into four depth ranges (Table 2-6 below). The majority of the submarine route is in relatively shallow water. Approximately 80.5% of the route, or 178 miles, is less than 547 meters (1800 feet) deep. About 27 miles of the route are between 547 and 1094 meters (1800-3600 feet) deep. The deepest portions of the route include 8 miles in the 1094-1641 meters (3600-5400 feet) range and 8 miles in the 1641-2188 meters (5400-7200 feet) range.

Table 2-6

APPROXIMATE DISTANCE WITHIN DEPTH RANGES FOR SUBMARINE ROUTE (KM)

		DEPTH RANGES			
		0-1800	1800-3600	3600-5400	5400-7200
Feet					
Meters		0-547	547-1094	1094-1641	1641-2188
Fathoms		0-300	300-600	600-900	900-1200

From	To				
Mahukona	Kohala Slope	27	5	-	-
Kohala Slope	Maui Slope	-	10	1	8
Maui Slope	Huakini Bay	7	2	7	-
Ahihi Bay	Waimanalo	<u>144</u>	<u>10</u>	-	-
TOTALS		178	27	8	8
PERCENT		80.5%	12.2%	3.62%	3.62%

Overland Route Segments

The information on overland route segments should be considered preliminary since there has been no public review or input into the constraint identification process. Readers are requested to not interpret this information as representing any conclusions or commitments to the selection of potential corridors. However, potential overland corridors were identified in two studies by DHM Planners, Inc. (1985 and 1988). The methodology used two steps, as follows:

1) Identification of four specific land uses which should be excluded from further consideration for transmission line corridors. These are termed Exclusion Areas, and they include:

- o Natural Area Reserves
- o Protective Subzones
- o National Parks
- o Military Impact Areas

2) Evaluation of 15 specific factors for the degree of constraint they pose to construction of 300 kVdc powerlines. These are termed Constraint Factors, and they include:

- o Geophysical
 - Slope and Soils
 - Geologic Hazards
 - Hydrology
- o Biological
 - Vegetation
 - Wildlife
- o Socio-Economic
 - Recreation
 - Land Use
 - Transportation & Utilities
 - Land Ownership
 - Visual Quality
 - History and Archaeology
 - Land Regulation
- o Costs
 - Land Value
 - Maintenance
 - Access

The criteria for designating areas for exclusion, and high, medium or low constraints are based on extensive reviews of data and information concerning each factor. The criteria and rationale are discussed in the report for each factor and the sources of information are provided. The constraint factors represent significant and discrete parameters of environmental sensitivity.

The exclusion areas and constraint factors are delineated using screens on mylar "overlays" placed over United States Geological Survey base maps. When placed on the base map and upon one another the overlays show areas ranging in shades of grey from black to white. "Exclusion areas" are shown as black, "high" constraint areas are dark grey, "medium" constraint areas are light grey and "low" constraint areas are white.

From the composite maps, the areas of "low" constraint are transferred to new maps and designated potential corridors. The potential corridors for Hawaii, Maui and Oahu are shown in Figures 2-13, 2-14 and 2-15, respectively.





FIGURE 2-15 POTENTIAL OVERLAND CORRIDORS ON OAHU

(The corridors depicted herein do not represent any conclusions or commitments to the selection of potential overland corridors.)



PART 3

ELECTRICAL GRID SYSTEM

Electrical Grid System Design Conditions/Criteria

The basic electrical grid system design conditions and criteria, as they affect the submarine cable system were identified and described by PTI (1984 and 1986) and specified in the System Feasibility Criteria (Parsons, 1985). They are as follows:

- o Maximum loss of power transfer requirement is 500 MW.
- o Maximum loss of power transfer on first single contingency is 125 MW.
- o Daily load swing on the cable system is expected to be from 500 to 200 MW.
- o Present projected annual peak on Oahu is 926 MW in 1992.
- o Annual load growth rate is 0.30 percent per year.
- o Annual minimum projected load on Oahu is 413 MW in 1987.
- o Range of feasible transmission voltages for grid system is 150 to 600 kV.
- o Surge arrestors to have capability to control impulse over-voltages to levels of 2.2 pu of normal system voltage.
- o System BIL requirement (775 kV) based on 20 percent margin between BIL level and highest impulse voltage to be experienced by the cable system. Based on CIGRE standards.
- o Internally and externally generated levels of switching surges on HVDC systems are relatively low. Highest switching surge type phenomenon is typically caused by single line to ground faults on the overhead line which can generate overvoltage levels up to 1.7 pu of system voltage.
- o Polarity reversal is assumed to occur. In the impulse range the reversal will be to a level of 2.15 pu in the reverse direction. In the switching surge and fundamental frequency range the reversal will be to a level of 1.0 pu.
- o A metallic return is considered a requirement for any cable system configuration due to sensitive and critical Department of Defense (DOD) and telecommunication cables.

- o All terminal equipment and interconnection facilities will meet the same normal load and single contingency requirement as the cable.
- o Commercial cable system to consist of two operating cables and one spare cable.
- o Expected low cable outage rate = once every ten years = unavailability of 5 percent.
- o Expected high cable outage rate = once every two and one-half years = unavailability of 20 percent.
- o Allowable cable outage duration is six months.
- o Cable system short circuit current and corresponding duration = 50 kV and one second.
- o Assumed cable spacing of 61 to 91.5 m (200 to 300 ft).

Subsequent work by PTI in Phase II-C allowed the following overall Program conclusions and recommendations to be made.

EVALUATION OF THE GEOTHERMAL DEVELOPMENT

PTI subcontracted with the Ben Holt Company to evaluate aspects of the potential geothermal development. The major conclusions of that study were that:

- 1) Evaluation of the production cycling potential of the geothermal system, based upon well test data from HGP-A and PGV wells, indicates the possibility that production can be cycled down by 90% in a single phase vapor system and by 60 to 70% in a two-phase system. However, further research and testing is necessary in order to confirm the feasibility of large scale geothermal development in the ERZ and to establish the ability of the reservoir to be cycled.
- 2) Of the four energy conversion systems evaluated in detail a single-pressure saturated steam cycle proved to be most economic in terms of capital expenditure; the installed costs ranging from \$1,794/kW to \$2,285/kW.
- 3) Energy costs were calculated based upon an assumption of a single, private ownership and operation of all plant facilities. The cost of energy was based upon revenue requirements for support of an unleveraged hurdle rate of 15% and for three different load factors. The 1995 bus bar costs of energy for the initial year of operation, 1995, are predicted to be \$0.124/kWhr, \$0.169/kWhr and

\$0.2155/kWhr for the three load factors, 100%, 85% and 75%, respectively. Based upon an 8% annual increase in the forecast price of fuel oil, the HECO production cost for 1995 will be \$0.0897/kWhr. For a 4% increase in oil cost the same energy cost is calculated to be \$0.062/kWhr.

ECONOMICS

A re-evaluation of the production and capital costs was performed in order to factor in new oil price forecasts, (4 and 8% escalation rates), new cable and installation costs and to include an evaluation of a smaller, 250 MW scheme. Further, a review of two-cable versus three-cable schemes was made. The results show that:

- 1) The installation of only two cables instead of three does not increase savings on an annual basis at commencement of the project. The two- and three-cable schemes are identical in cost savings until the year 1999 when the three-cable scheme begins to show lower savings because the cost of financing the third cable is then added. However, as time progresses the difference between the schemes diminishes. For all cases except a low fuel escalation rate coupled with a high FCR, the three-cable scheme has equal or higher savings than the two-cable scheme in the later years because of its higher availability.
- 2) Reducing the size of the scheme, to 250 MW, as would be expected, results in a reduced capital outlay initially and payback is apparently faster. There are initially negative net savings, however, if the Fixed Charge Rate (FCR) is high enough and/or the fuel price is low enough. The 500 MW scheme makes available more dollars per MWhr imported, on a flat present worth basis, than does the 250 MW scheme for all combinations of parameters.
- 3) The ratio of dollars saved to energy purchased from the geothermal resource is higher, by about 10% (on a total 20 year present worth basis) with the 500 MW scheme than it is for the 250 MW scheme.
- 4) While economy of scale makes a 250 MW scheme more expensive, in terms of dollars per installed kilowatt, the 250 MW scheme is more attractive from the financial point of view because of its higher load factor.

OPERATION

The system can be operated with down to only three units on line at minimum load without losing frequency control. They also demonstrate the need for up to 400 MVAR of installed voltage controlled devices. A large percentage of that required total would be installed at the inverter station to supply the inverter (250 MVAR). The rest is a system requirement which can be met in several ways.

- o Installation of switched capacitor banks at strategic locations
- o Additional capacitive support at the inverter controlled by the HVDC control
- o Use of synchronous condensers (rotating machines for reactive power generation)
- o Thyristor switched capacitors
- o Convert redundant generation to synchronous condenser operation

HVDC Configuration

In terms of economics, the specifics of the dc configuration are not of paramount importance. Whether or not a bipole or monopolar arrangement is used, the total amount of equipment and cable will be essentially the same. The bipole is the most efficient configuration as it minimizes ground return and electrode requirements. What is important with a bipole is that the two poles should be independent, that is, no single contingency outage should result in loss of both poles.

The bipole arrangement should, therefore, depend upon duplication of services, such as cooling and auxiliary power supplies, in order to separate operation of the two poles. The complete isolation of the poles, however, is not possible since some communication between them will be necessary. Loss of a pole, for example, will call for an increase in power transmitted on the remaining pole such that effectively only 125 MW of transmission capability is lost. That is no worse than loss of the largest unit in the HECO system, a contingency which will normally be accounted for by spinning reserve.

It is important therefore to recognize that a bipolar arrangement is convenient for minimization of ground return but must be engineered in such a way that the poles are quasi-independent. With a bipole, both electrode requirements and potential interference problems are minimized.

For the HVDC equipment itself, the choice lies between having only one valve-group per pole or two. The former has the advantage of being initially less costly but other factors demand use of two 125 MW valve-groups per pole as opposed to one 250 MW valve-group. Firstly, the project is presently programmed to be developed over about a 10 year period. This allows for building the system in parts. It is convenient to divide the system into four parts, each of 125 MW, in order to match the generation development. This immediately removes the possibility of losing 250 MW whenever a valve-group outage (the most common) occurs. Secondly, during maintenance, which comprises the highest cause of system unavailability, no power is lost with a valve-group out of service since the remaining three valve-groups are sized for a 150% capability. In terms of costs the two valve-group scheme is not necessarily more expensive because half the investment is delayed on each pole.

In terms of cable configuration, previous studies demonstrated the superiority of the three-cable scheme over the four-cable and two-cable schemes in terms of reliability and cost.

Evaluation and preliminary design work was done on the overhead transmission part of the HVDC project. In summary, it was shown that for bipolar structures, guyed towers are the least expensive of the three alternatives studied; those being guyed, self-supporting lattice and steel pole. What was further shown, however, is that it would be less expensive to build two monopolar, wooden structures, (each independently carrying one, 250 MW, pole conductor). These could be constructed on separate Rights-of-Way (ROW) in order to obviate the possibility of losing the entire system as a result of a major line contingency.

The reliability studies, performed during Phase II-B, evaluated the relative performances of schemes with and without a metallic return cable for various operating criteria and quite clearly showed that a scheme with sea return which allows ground current to flow freely would be the most reliable.

MECO TAP

For a tap configuration there are three main parameters associated with its design. They are:

- o Series or Parallel tap
- o Tap rating
- o Tap polarity

In general a series tap is expected to be less expensive than a parallel tap if its rating is about 10% or less of the main bipole rating. Cost information received from manufacturers

support this idea but show that the differences are not significant. What will determine the tap type is related to the main bipole structure. If the +300 kV bipole is constructed in four stages such that for some time the poles will operate at 150 kV, such operation will obviate the use of a parallel tap or will call for a doubling of its converter transformer turns ratio when the pole voltage increases to 300 kV.

The rating of the tap is a wide open question which can be answered in part by MECO's generation expansion plans. Those plans should specifically define the balance of power, needed on the island, which could be imported.

AC SYSTEMS

The three island systems will need to be connected to the HVDC three-terminal system by modification to their existing networks.

For Oahu, system studies showed that the two probable sites at Aniani and Meadowlands were essentially equivalent in terms of performance and cost of modifying the 138 kV network to accommodate the incoming power. On balance it is seen that the Aniani site is less environmentally sensitive, is closer to the cable landing point and is central to two large load substations at Koolau and Pukele.

Three converter sites on Hawaii were investigated in the system studies. They were at Mahukona on the north-west point of the island, at Kaumana near Hilo and at a site near Puna. The Mahukona site involved crossing the island with ac lines from the geothermal sites to a distant rectifier station. That configuration is very expensive and difficult to operate since it moves the rectifier away from the strength of the system to one of low short-circuit level. A site at Kaumana works well since it is relatively close to the resource. However, it would be best to locate the rectifier station as electrically close as possible to the geothermal units, which suggests a site somewhere in the Puna region.

The MECO network comprises a 69 kV loop which is presently fed from two MECO stations at Maalaea and Kahului; the latter via the low voltage network. The siting for a tap location will in all probability be determined by available space and environmental considerations. Studies have shown that from an electrical viewpoint the tap functions at any point in the southern part of the 69 kV loop. The cable route parallels the southern shore of Maui and so it makes sense that the tap location will be at that side of the island. The criterion should be to select a site as close to Maalaea as possible since this is the central point of the 69 kV network while minimizing the cross-island dc requirements.

PROJECT SCHEDULE

Figure 3-1 shows a conceptual schedule for a 10 year development plan while Figure 3-2 indicates the relevant configuration stages. The major aspects of the schedule are that;

- Geothermal unit installations progress linearly in time with the first unit being ready for operation as the first part of the transmission system is completed.
- Unit size is 25 MW or 50 MW. The Ben Holt report indicates that a 50 MW unit size is the optimum rating. This is supported to some extent by existing installations.
- The transmission capacity grows with installed capacity.
- The cable availability and timetable is based upon information received from Pirelli.

What is indicated by Figure 3-1 is that the geothermal development drives the overall timetable although that development is arbitrary. From a transmission viewpoint, 500 MW could be transmitted by the time the second cable is commissioned. This highlights the need for an analysis of the possible timetable for source and generation development. That analysis needs to account for financing and investment possibilities since to accelerate the generation program implies significantly greater levels of financing earlier.


OPERATION


The fundamental question of cycling the 500 MW geothermal installation has been partially answered by the Ben Holt report on the basis of available information on the resource. There it is stated that the output from a 500 MW installation can be cycled down on a daily basis to 150 MW without incurring any cost additions over that which would be required for an installation which does not cycle but is base loaded. Consequently we have as a basis ten 50 MW units connected to the HECO grid which have a minimum load of 15 MW each.

Secondly, there is a need to unload the existing HECO units in order to maximize import from Hawaii. This implies not only taking units off line but selecting units which are ostensibly base load plants and modifying their operation such that they can go to two-shift operation or operate at minimum loading less than currently allowed. This is to specifically maximize imports during minimum demand periods. System operation was studied by


FIGURE 3-1

CONCEPTUAL SCHEDULE FOR HDWC/HVDC PROJECT







STAGE 1



STAGE 2



STAGE 3



STAGE 4

CABLE CONVERTER STAGING

FIGURE 3-2

using a Unit Commitment program to identify the manner in which the geothermal units and the existing HECO units would operate over typical daily load cycles on the basis of different numbers of 'must-run' or base loaded HECO units. The constraints imposed on the units were the known ramping rates, maximum and minimum loading and system spinning reserve requirements.

What was seen in the results of that study was that there is no significant problem in plant operation or in ability to load follow for the combination of HECO and geothermal units, given that some of the present 'must-run' units could be modified to operate in a two-shift mode. It was further seen that based on cost, reducing the existing number of must run units below three or four was not cost effective since start-up costs negate savings in fuel cost.

PART 4

CABLE SUBSYSTEM

The cable design selected for final design, fabrication, testing and interfacing with other subsystems is Pirelli Cable Corporation (PCC) Design Case No. 116 (see Table 4-1). Figure 4-1 shows a cross-section of this cable, and Table 4-2 lists the dimensions of the layers shown in the figure. The following additional parameters apply to this cable:

1. A three-cable system will be employed--two operating cables plus one spare.
2. Seven factory splices, one at-sea splice and two ship loadings per cable length (Big Island to Oahu) will be required.
3. The maximum allowable conductor temperature is 85 degrees C. Expected conductor temperature at rated load is 48.6 degrees C.
4. E-type lead alloy will be used as the sheath material.

Table 4-1

SELECTED BASIC DESIGN CHARACTERISTICS OF CABLE DESIGN NO. 116

PARAMETER	DESCRIPTION
Cable Type	SCOF
Voltage	+300 kVdc
Conductor Cross Section	1,600 sq mm (2.48 sq in)
Total Transmission Load, Bipolar	500 MW
Transmission Load Per Cable	250 MW
Rated Current Per Cable	833 amps
Conductor Material	Aluminum
Conductor Type	Hollow Core Segmental Strip (Keystone)
Design Electrical Stress	35 kV/mm (cold and hot)
Oil Duct Diameter	25 mm (0.98 in)
Oil Type	High density synthetic low viscosity
Number of Cables for System	2 plus one spare
BIL	775 kV
SIL	580 kV*
Polarity Reversal	Allowed
Conductor Diameter	51.9 mm (2.043 in)

Insulation Thickness	10.9 mm (0.429 in)
Cable Finished Diameter	118.4 mm (4.66 in)
Cable Weight in Air	37 kg/m (24.9 lb/ft)
Cable Weight in Water	27 kg/m (18.2 lb/ft)
Maximum Oil Feeding Length	190 km (118.1 mi)
Design Oil Feeding Pressure	30 atm (440 psi)
Conductor Resistance	0.0179 ohm/km
Losses at Rated Current Per Cable	12.4 kW/km
Actual Maximum Cold Screen Stress	32.1 kV/mm
Actual Maximum Hot Screen Stress	30.6 kV/mm
Ratio Between Actual and Design Stress	0.92
Electrical Design Safety Factor	3.27
Pulling Tension for 7,000 ft Water Depth (Based on PCC Formula)	65.1 mt (71.8 t)
Maximum Allowable Cable Pulling Tension	78.7 mt (86.8t)
Corresponding Maximum Water Depth (Based on PCC Formula)	2,626 m (8,615.5 ft)
Minimum Allowable Bending Diameter During Installation:	
a-Without Tension	7.0 m (22.97 ft)
b-With 7,000 Ft Pulling Tension	11.6 m (38.06 ft)
c-With Maximum Allowable Pulling Tension	12.0 m (39.37 ft)
Mechanical Design Safety Factor	3.02
Initial Maximum Allowable Squeeze Per Unit Length	3.00 mT/m
Total Cable Unit Cost of Which:	306 \$/m
a-Material Cost	49 \$/m
b-Incremental Manufacturing Costs	247 \$/m
Unit Capital Transmission Cost Per Cable	1,224 \$/MW km

* Assumed value.

The basic construction of the SCOF cable type is as follows:

- o Conductor: Aluminum hollow core segmental strip (keystone) conductor. The strips are applied with suitable stranding pitch in two, three or four layers according to conductor size. Oil duct inside the conductor 25 mm (1 in) or alternatively of 50 mm (2 in).
- o Shield Over Conductor: Carbon black paper tapes.

FIGURE 4-1

WEIGHT OF CABLE IN AIR: 37kg/m (24.9 lb/ft)
 WEIGHT OF CABLE IN WATER: 27kg/m (18.2 lb/ft)




CABLE CROSS-SECTION

Serving

2nd Armor

Binding

First Armor



Lead alloy sheath

Semicon. cotton tape-Reinforcement-semicon cotton tape

Polyethylene semicon jacket

Treated cotton tape - Antiteredo protection

Bedding

Oil duct

Aluminium conductor

Conductor shield

Insulation

Insulation shield and protection

SCALE NTS	DRAWN BY SC/pb	Self Contained Oil Filled Cable 1x1600 mm ² - 300 kV d.c.	
DATE 3/85	APPRD BY LB		HAWAII DEEP WATER CABLE PROGRAM
			B/M
			DRAWING NO. 2

- o Insulation: Deionized water washed wood pulp paper suitably graded in thickness and impregnated with high density synthetic low viscosity (highly aromatic hydrocarbon) synthetic oil. Application of tapes with predetermined lapping tensions in conditioned room.
- o Shield Over Insulation: Carbon black duplex type paper plus carbon black paper intercalated with metallized paper.
- o Protection of the Insulated Core: Copper woven fabric tape binder overlapped.
- o Lead Alloy Sheath: Type E.
- o Semiconductive Textile Tape Bedding
- o Reinforcement of Multilayer Bronze Tapes
- o Special Anticorrosion Bituminous Compound
- o Textile Tape
- o Polyethylene (PE) Jacket
- o Textile Tape
- o Antiteredo Copper Tape
- o Bedding of special polypropylene yarn of suitable thickness and suitably applied.
- o First Armor: One layer of 3 mm (0.12 in) thick flat wire of high strength galvanized steel (breaking strength of 120 kg/mm²). The flat wires are applied with a suitable laying pitch.
- o Special Anticorrosion Bituminous Compound
- o Binding of special polypropylene yarn of suitable thickness and suitably applied.
- o Second Counterhelical Armor: One layer of 3 mm (0.12 in) thick flat wire of special high strength galvanized steel (breaking strength of 120 kg/mm²). Flat wires are applied with a suitable laying pitch in direction opposite to that of the first armor.
- o Special Anticorrosion Bituminous Compound
- o Serving of special polypropylene yarn suitable applied.

Additional Considerations for Cable:

- o A low resistance connection between lead sheath and armors is required in order to reduce induced overvoltages on the jacket. This can be accomplished by use of a semiconducting jacket or by metallic connections at predetermined intervals.
- o Both cable types (Solid and SCOF) should be wound during manufacture, storage, transportation and laying on turntables due to their double counterhelical armor design and in order to avoid any twisting to the cables. Coiling on fixed platforms is not possible.
- o The parametric study (PCC, December 1984) is valid for both the F-3 and E Type lead alloys. The use of Alloy E is considered preferable for submarine cables because of its comparable mechanical properties and its superior extrudability.

**Table 4-2
CABLE DIMENSIONS (NOMINAL)**

Components	Layer Thickness	Diameter
Al conductor (1600 mm ²)	oil duct 25 mm (0.98 in)	51.9 mm (2.043 in)
Conductor shield	0.6 mm (0.024 in)	53.2 mm (2.094 in)
Insulation	10.9 mm (0.429 in)	75.0 mm (2.953 in)
Insulation shield	0.2 mm (0.008 in)	75.5 mm (2.972 in)
Core protection	0.3 mm (0.012 in)	76.2 mm (3.000 in)
Lead sheath	3.3 mm (0.130 in)	82.8 mm (3.260 in)
Bitumen	--	--
Semiconducting cotton binder tape	0.3 mm (0.012 in)	83.4 mm (3.283 in)
Bitumen	--	--

Bronze tapes	0.6 mm (0.024 in)	84.6 mm (3.33 in)
Bitumen	--	--
Semiconducting cotton binder tape	0.45 mm (0.018 in)	85.8 mm (3.378 in)
Polyethylene jacket	4.0 mm (0.157 in)	93.8 mm (3.693 in)
Treated cotton bedding tape	0.34 mm (0.013 in)	94.5 mm (3.720 in)
Antiteredo tinned copper tapes	0.1 mm (0.004 in)	94.7 mm (3.721 in)
Polypropylene yarn bedding	1.1 mm (0.043 in)	96.9 mm (3.815 in)
First flat steel armor	3.0 mm (0.118 in)	102.9 mm (4.051 in)
Bitumen	--	--
Polypropylene yarn bedding	1.6 mm (0.063 in)	106.1 mm (4.177 in)
Second counterhelical armor	3.0 mm (0.118 in)	112.1 mm (4.414 in)
Bitumen	--	--
Polypropylene yarn serving	3.3 mm (0.130 in)	118.7 mm (4.673 in)

PART 5

CABLE VESSEL SUBSYSTEM

Design of the vessel for a potential commercial cable laying operation was the subject of the report System Analysis and Parametric Studies (HD&C, et al., 1984). Since the adoption of a "reduced-scale At-Sea Test," vessel analyses focused on selection of an appropriate platform for the At-Sea Test, rather than on further design of a commercial vessel. A description of the vessel selected for the At-Sea Test is included in Part 7. The remainder of this section provides details about a generic vessel appropriate to a commercial cable deployment in the Alenuihaha Channel.

Cable Vessel: (Preliminary)

Flat Deck, Ocean-Going Cargo Barge
122 m (400 ft) x 30.5 m (100 ft) x 7.63 (25 ft)

Propulsion System:

For the HDWC Program Two Thrusters Attached to Vessel.
Attachment Location To Be Determined.

Total Cable Tension From Vessel:

(See Figure 5-1)

Cable Laying Environmental Loading:

(See Figure 5-2)

Design Barge Forces:

(See Figure 5-3)

Principle Cable Vessel Subsystem Feasibility Criteria:

- o Vessel must have adequate deck space and be structurally designed for the cable and cable handling equipment and deployment/retrieval/repair operations.
- o Vessel must be able to maintain predetermined bottom path for deployment/retrieval operations and maintain position during repair operations.
- o Vessel must be able to maintain stability requirements for deployment/retrieval/repair operations.

Total Tension From Vessel:

(See Figure 5-1 and Tables 5-1 and 5-2)




FIGURE 5-1

TOTAL TENSION FROM VESSEL
400-Foot Barge, Stern Depth 32.14 kg/m

TABLE 5-1
INPUT DATA FOR VESSEL TV GRAPH

DEPTH	DEPTH (FT)	SEA STATE	η	Wxh	Tv
2,133.60	7,000	4	0.70x0.30	68.6	96.5
1,524.00	5,000	4	0.37x0.70	49.0	75.2
1,005.84	3,300	4	0.70x0.40	32.3	54.9
2,133.60	7,000	6	0.87x0.30	68.6	100.0
1,524.00	5,000	6	0.37x0.87	49.0	78.2
1,005.84	3,300	6	0.87x0.40	32.3	57.1
2,133.60	7,000	8	0.30	68.6	102.6
1,524.00	5,000	8	0.37	49.0	80.6
1,005.84	3,300	8	0.40	32.3	58.8
2,133.60	7,000	12	0.37	68.6	107.4
1,524.00	5,000	12	0.00	49.0	82.2
1,005.84	3,300	12	0.44	32.3	60.1

Assumes: 400 ft barge, stern cable deployment baseline cable = weight 32.14 kg/m wet. Uses algorithm: $Tv = Wxh + T_{bot} + \eta W_h$.

Note: Figure 5-1 and Table 5-1 to be recalculated following selection of specific vessel and determination of equipment weight distribution.




FIGURE 5-3
DESIGN BARGE FORCES

Table 5-2

SUMMARY OF TENSION DYNAMIC AMPLIFICATION FACTORS
 FOR THE BASELINE CABLE AND THE GENERIC BARGES
 CONSIDERED UNDER SEA CONDITIONS OF SIGNIFICANT HEIGHT
 2.4 M (8 FT) AND 5.5-SECOND PEAK PERIOD
 (CABLE ATTACHMENT AT STERN OF BARGE IS ONLY GIVEN HERE)

BARGE	DRAUGHT	WATER DEPTH	DYNAMIC AMPLIFICATION (N) ²
122 m x 23 m ¹ . (400 ft x 75.4 ft)	3.1 m (10.2 ft)	2,134 m (7,000 ft)	0.30 ³
122 m x 23 m ¹ . (400 ft x 75.4 ft)	3.1 m (10.2 ft)	1,000 m (3,280 ft)	0.40 ³

1. 122 m (400 ft) x 30.5 m (100 ft) barge to be modeled following determination of vessel layout and weight distribution on deck.

2. n for 122 m (400 ft) x 30.5 m (100 ft) barge in 1.8 m (6 ft) and 3.7 m (12 ft) seas to be modeled following determination of vessel layout and weight distribution.

3. Derived using a baseline cable of:

133.0 mm (5.25 in) Diameter
 46.4 kg/m (31.2 lb/ft) Dry Weight
 32.1 kg/m (21.6 lb/ft) Dry Weight

NOTE: The selected cable is significantly lighter than this baseline cable (see Part 4, Cable Subsystem).

PART 6

CABLE HANDLING EQUIPMENT SUBSYSTEM

Preliminary design work for the Cable Handling Equipment Subsystem was completed in 1985 by Western Gear Machinery Co. As was the case for the Cable Vessel Subsystem, once the reduced-scale At-Sea Test concept was adopted, design efforts focused on equipment suitable for the test rather than for the commercial cable deployment. Cable Handling equipment for the test will be provided aboard the vessel, and no major additional design, fabrication or procurement efforts were necessary.

The most significant systems development effort has been that of the Control and Operating Equipment. This system is applicable to both the test and a commercial deployment, and is described in Part 7.

Cable Handling Equipment Preliminary Design Criteria and Estimated Dimensions: All cable handling equipment and controls to be designed and sized to handle Cable Design No. 116.

Preliminary Equipment Outline Dimensions Layout: (See Figure 6-1)

Overboard Sheave:

Sheave radius over guards = 6.6 m (21.6 ft)
Sheave width over guards = 2.0 m (6.6 ft)
Sheave width over hub = 3.0 m (9.8 ft)

Dynamometer:

1.0 m (3.28 ft) high x 0.75 m (2.5 ft) wide x 2.25 m
(7.4 ft) long

Length of device to be parallel to cable travel

Sensor Platform:

0.75 m (2.5 ft) high x 0.5 m (1.64 ft) wide x 1.25 m
(4.1 ft) long

Length of device to be parallel to cable travel

Linear Tensioner:

3.75 m (12.3 ft) high x 5.0 m (16.4 ft) wide x 32.0 m
(105 ft) long




FIGURE 6-1
CONCEPTUAL DRAWING OF THE MAJOR
CABLE HANDLING MACHINERY
FOR THE HDWC PROGRAM

Pickup Arm:

Pickup arm is cantilever as shown on Figure 6-1. Vertical (wall) mounting surface is located approximately 5.0 m (16.4 ft) from the outside diameter of the turn-table.

Cable Storage/Turntable:

Turntable dimensions for the HDWC Program to be defined following discussions with owners of existing equipment and additional preliminary design studies. The minimum inside (hub) diameter of the turntable is 7.0 m (23 ft) and the outside diameter of the turntable is 10.0 m (32.8 ft) for the HDWC Program.

Troughing:

Metal troughing will be used where it is needed such that the cable is continuously supported throughout its passage through the cable handling equipment. This is necessary to prevent cable bend diameter violation and/or hangups during low tension operations.

Assume metal trough is a "U" shaped sheet metal device approximately 30 cm (22.8 in) wide with length and support as required.

Controls:

Assume all controls to be within the integrated control center.

Principle Cable Handling Equipment Subsystem Feasibility Criteria:

- o Cable handling equipment must be able to maintain appropriate cable tension during deployment/retrieval/repair operations. Acceleration in one min. to one min./sec., payout one min./sec., takeup rate 0.5 min. per/sec.
- o Cable handling equipment must be able to load cable from dockside storage to onboard storage at the rate of 2 min./sec.
- o Cable handling equipment controls must be fully integrated and designed to handle all foreseen emergency conditions.

PART 7

THE AT-SEA TEST

CABLE

The cable selected for the At-Sea Test (AST) is a wire rope smaller, lighter, and much less expensive to fabricate than Cable No. 116. This is to allow use of an existing vessel and handling equipment. The weight to diameter ratio, however, has been matched to that of Cable No. 116 so that controlling the bottom position and tension will be equally as difficult for this "surrogate" cable as for No. 116.

A cross-section of the surrogate cable is shown in Figure 7-1 and technical data are listed in Table 7-1.


Table 7-1

TECHNICAL DATA ON SURROGATE CABLE

PARAMETER	VALUE
Length	8,000 meter, unspliced
Type	Full-locked coil, torque-balanced
Young modulus	15,000 daN/mm ² ± 500
Moment of inertia (Stiffness)	20.90 x 10 ⁶ kg-mm ²
Minimum bending ratio	80/1 @ 20 mt tension (dynamic) 35/1 @ 3 mt tension (static)
Minimum sheave diameter	3.6 M
Recommended sheave diameter	4.5 M
Sheave shape	V
Thermal coefficient of expansion	11.5 x 10 ⁻⁷ /°C/m ± 2%
Coeffiecient of friction (expected)	0.15 (steel/steel) 0.25 (steel/pur)
Torque	Maximum 161.7 N-m (under 60 MT)
Rotation	Maximum 30°/100m (under 60MT)
Squeeze	Maximum 2% at max. tension = (40 MT) Maximum radial pressure of 15 kg/mm ² on the outer wire rope surface with ± 0.2% maximum change in diameter. Maximum squeeze at zero tension 1%
Standing angle	15° for round wires 23° for "2" wires
Composition	bright steel round wires, drawn galvanized steel for "Z" wires
Outer layer pitch	303.8 mm (11.96 in)

FIGURE 7-1

Diameter: 45.0 mm
Rupture: 1885.00 KN



Nominal diameter	45 mm (1.775 in)
Cross-section	1334.54 mm ² (2.068 in ²)
Nominal breaking strength	1885 KN (423.69 kips)
Weight (in air)	11.45 kg/m (7.626 lbs/ft)
(in sea water)	9.86 kg/m (6.590 lbs/ft)
Cable filling	amorphous polypropylene

Cable Vessel

The vessel M/V Flexservice 3, operated by Coflexip, has been selected for the AST. It is described in Table 7-2 and shown in Figure 7-2.

Table 7-2

TECHNICAL DATA ON FLEXSERVICE 3

PARAMETER	VALUE	
Classification	DNV + 1 A1 - SUPPLY VESSEL - SF - EO DYN POS AUTR (ERN: 99, 99, 93)	
Length overall	83.20 m	273'
Length between p.p.	75.20	246'9"
Breadth overall	19.80 m	65'
Breadth moulded	19.40 m	63'8"
Depth (main deck)	4.67 m	16'4"
full scantling	5.89 m	19'3"
Draught (summer freeboard)	5.12 m	16'10"
full scantling	7.00 m	23'
Deadweight	3050 metric tons at 5.12 m	
full scantling	5400 metric tons at 7 m	
Gross tonnage	1600 GRT at 5.12 m draught	
Deck cargo	about 3600 tons with center of gravity placed 1.65 m above deck	

Deck loading	10 tons/sqm
Clear deck area	52.0 m x 17.0 m = 884 sqm
Water ballast/drill water	2420 tons + 140 tons for pipes pressure test
Drill water discharging	2 x 100 tons/hr against 9 bars
Fresh water generator capacity	1 x 12 tons per day
Fuel	
- heavy fuel oil	790 CBM
- gas oil	985 CBM
Fuel oil discharging	1 x 250 CBM/hr against 9 bars
Bulk cement/mud	6 vertical tanks, each 2000 cuft total 12000 cuft (340 CBM)
Bulk discharge rate	2 x 20 CBM/hr at 5 bars

Other relevant vessel equipment is as follows:

Navigation Equipment

- 2 Decca radars, type RM 916 C (1 X 10 cm, 1 X 3 cm)
- 1 Furuno SFP radio direction finder
- 2 Robertson Gyro SKR 80 with auto pilot AP.8
- 1 Simrad echosounder ED 38
- 1 Simrad navigation log
- 1 Satellite navigator, type MAGNAVOX

Radio Communication Equipment

- 1 main radio transceiver, type SAILOR 80 SSB, 800 W frequencies: SW/MW
- 1 Siemens sell call C X 2
- 1 mobile VHF emergency transmitter radio beacon
- 1 mobile VHF emergency communication set




FIGURE 7-2

FLEXSERVICE 3 BASIC EQUIPMENT	
1/1/55 AT 1/1/55	5060FS 25

- 1 internal ship calling system including speaker on aft deck
- 1 lifeboat emergency transmitter
- 1 UHF
- 1 international telex

Cable Handling Equipment


The major items of equipment required to lay the selected surrogate cable in the water depths involved and to the specification given are:

- o a reel to store the surrogate cable (Figure 7-3) and a winch to lift and allow rotation of the reel (Figures 7-4 and 7-5).
- o a reel to store the abandonment and retrieval rigging and a winch to lift and rotate the reel (Figure 7-6).
- o a reel and winch to deploy and retrieve the abandonment and retrieval rigging. A resourceful rigging design indicates that the deployment reel be separate from the storage function.
- o a tensioner (Figure 7-7) capable of deploying and retrieving the surrogate cable.
- o an overboarding sheave (Figure 7-8).

Cable Handling Control and Data Acquisition Systems

Descriptions of the final designs of the cable laying control and data acquisition systems are contained in Makai and Noda (1988). Because of the very high accuracy required for positioning and tensioning, a computerized control system is being developed to precisely lay the cable.

The overall control for the cable laying process is illustrated in Figure 7-9. The goal of the cable laying control system is to accurately place and properly tension the cable on the bottom, and the system output is instructions for the vessel to proceed along a particular course and instructions for the cable tensioner to pay out the cable at a specific speed. Corrections are constantly being made to these instructions provided to the tensioner and the vessel dynamic positioning system based on differences computed between the desired cable touchdown conditions and the actual touchdown conditions. In order to determine the actual touchdown conditions, the cable shape must be constantly computed based on input information such as ship



TOTAL WEIGHT: $28 + (1 \times 2) = 30T$
 FIGURE 7-3 DEPLOYMENT REEL FOR
 SURROGATE CABLE

Rev	0	FIRST ISSUE
Mod		Modification
Date		

MMI2	
Date	
Drawn	
Checked	

REEL 78 x 44 x 50 AND SUPPORTING CRADLE 7m	
Material	Treatment
Ch / Scale	Pl / Sheet
1/50	A 3
N° 108-3-0002	
Quantity / Weight	30 T


Drawn by: *WJ*
 Date: 14.04.82
 Checked for: E.B.
 Date: 14.04.82
 Approved by:



FIGURE 7-4

TR 23 WINCH

Used with TR25A, TR34 (cargo rail)
or TR25A+L, TR34+L, TR33



MAIN FEATURES

 (All features include the use of TR25)
 Output power : 105kw (hydraulic motor driven)
 Loading capacity : 2000kN (440900lbs)
 Spool type : 78.44.50
 : 55.26.50
 Maximum torque : 700mkN (505900 ftlbs)
 Maximum pull : 318 kN (70100 lbs) , with 78.44.50 spool
 Revolution per min. : 0 to 2.2
 Spooling device : Not fitted

Dimensions Length : 5.00m (16 ft 5in)
 Width : 2.15m (7ft)
 Height : 4.85m (15ft 11in)
 Weight : 225kN (49600lbs)

Power pack Length : 3.40m (11ft 2in)
 Width : 1.50m (4ft 11in)
 Height : 1.70m (5ft 7in)
 Weight : 18kN (3900lbs)

POWER INPUT


 Power pack (elect) : 117kw, 3x440v/60hz
 Elect. cable : 750MTH-4x70mm², PDO2047001
 Seawater cooling : 3m³/h at 0.3MPa
 Seawater hose : 2in, PD05000055
 Hose coupling : 2in, PH.....



FIGURE 7-5

TR 25 WINCH

Used with TR23A, TR33,
TR25A+L, TR34+L



MAIN FEATURES

(All features taken with use of TR23A, TR33, TR34+L)
Output power : 105kW (hydraulic motor driven)
Loading capacity : 2000kN (440900lbs)
Spool type : 78.44.50
 : 55.26.50
Maximum torque : 700mkN (505900 ftlbs)
Maximum pull : 318 kN (70100 lbs) , with 78.44.50 spool
Revolution per min. : 0 to 2.2
Spooling device : Not fitted

Dimensions Length : 6.45m (21ft 2in)
 Width : 2.50m (8ft 3in)
 Height : 6.00m (19ft 8in)
 Weight : 225kN (49600lbs)

Power pack Length : 3.40m (11ft 2in)
 Width : 1.50m (5ft 11in)
 Height : 1.70m (5ft 7in)
 Weight : 35kN (7720lbs)


POWER INPUT

Power pack (elect) : 117kw, 3x440v/60hz
Elect. cable : 750MTH-4x70mm², PDO2047001
Seawater cooling : 3m³/h at 0.3MPa
Seawater hose : 2in, PDO5000055
Hose coupling : 2in, PH.....



FIGURE 7-6

TR 7 WINCH



MAIN FEATURES

Output power	:	88kw (hydraulic motor driven)
Loading capacity	:	2000kN (440900lbs)
Drum type	:	80.44.54
Maximum torque	:	1100mkn (795000 ftlbs) at 0.5rpm 600mkn (433600 ftlbs) at 0.8rpm
Maximum pull	:	500kN (110230lbs) at 0.5rpm 273kN (60120lbs) at 0.8rpm
Revolution per min.	:	0 to 0.8 (see above)
Spooling device	:	2m/min (6ft 7in/min)
Dimensions	Length	: 8.80m (28ft 11in) with spooling 8.00m (26ft 3in) without spooling
	Width	: 8.00m (26ft 3in)
	Height	: 8.40m (27ft 5in)
	Weight	: 790kN (174100 lbs) winch only 50kN (11025lbs) spooling


POWER INPUT

Power pack (elect.)	:	88kw, 3x440v/60hz
Elect. power cable	:	750MTH-4x70mm ² , PDO2047001
Seawater cooling	:	3m ³ /h at 0.3MPa
Seawater hose	:	..in, PD.....
Hose coupling	:	..in, PH.....



FIGURE 7-7

50 TON TENSIONER



CARACTERISTIQUES / CHARACTERISTICS

Puissance	Power	125 kW
Tension	Voltage	440 V
Frequence	Frequency	60 hz
Dimensions	Sizes	E
		F
		G
		C
		A - length in contact with pipe
		D
Vitesse	Speed	0 to 10 m/min
Couple	Torque	
Tension	Pulling strength	500 kN
Charge	Load	
Poids a vide	Weight empty	450 kN




FIGURE 7-8

229 818	2	5	22	Section N 14 30 70	Cluster W 8	Control
229 819	1	1	1	JANTE (SECTION)	1st JANTÉ 176	
229 819	1	1	1	MOTEU	1st JANTÉ 176	
Plan N	Map	Scale	Designation	Material	Dimensions	Remarks
Drawing N°	Scale	No.	Description	Designation	Material	Dimensions
CP COFLEXIP						
OVERBOARDING SHEAVE						Weight 11.86 3.07.85
Material				Statement		BT 019
Method				Treatment		
Date				Drawing Size		PL 1 SHEET
1/20				A1		N° 141.1.005

PJ 14110005

Issued for CONSTRUCTION	U.S.	Scale
Modification	Date	Drawn
Modification	Date	Checked


position, currents, cable transponders, etc. Much of the control loop concentrates on these computations.

In order to properly compute cable touchdown conditions and the cable bottom tensions, the controller requires accurate measurements of the information shown on the left of Figure 7-9. Under most circumstances, accurate knowledge of the current profile, vessel navigation, cable payout, the planned path including bathymetry, and the history of the cable lay is adequate to determine a sufficiently accurate touchdown point and tension. For cases of very high tension or position accuracies, transponders will be added to the cable to reduce the computation error.

The Data Acquisition system is provided on the cable vessel to achieve the two secondary goals of the At-Sea Test: recording the performance of the control system and recording the dynamics of the waves, ship and top cable tensions. These data will be used after the test to evaluate the performance of the control system and to perform an independent study of the dynamics of the suspended cable and ship.

The basic control loop for the integrated system is illustrated in Figure 7-10 and each of the blocks are described below:

1. Ship and cable sensors provide the basic input information to the control computer (see Figure 7-9).
2. The Actual Path Calculator (APC) is a subroutine which, by iterative process, computes the actual cable touchdown point and bottom tension. It solves a mathematical model of the cable computing the position and the forces along the suspended cable length.
3. The comparator determines the difference between the actual touchdown values and the desired values.
4. The planned cable track on the bottom is corrected, if necessary, to bring the cable back to the desired path in the immediate future.
5. The Vessel Response Specifier (VRS) is a subroutine which computes the ship's course and speed and the cable payout speed in order to achieve the desired cable path and tension specified in Step 4, above. This subroutine provides instructions directly to the vessel and cable handling equipment crew.
6. The ship's captain and cable handling equipment operator receive the instructions from the Vessel Response Specifier. The ship and the cable handling equipment respond to their directions and the ship and cable sensors monitor the performance. Hence, the control loop returns to Step 1.



INPUTS/OUTPUTS TO INTEGRATED CONTROL SYSTEM

FIGURE 7-9.

BASIC CONTROL SYSTEM LOOP




FIGURE 7-10

At-Sea Test

The At-Sea Test for the HDWC Program will involve repeatedly laying a surrogate cable across the more difficult regions of the Alenuihaha Channel. The major components of this At-Sea Test are illustrated in Figure 7-11. Two primary vessels will be used: the cable ship and a support vessel. The primary function of the cable ship is to lay the cable and on that vessel will be the Integrated Control System, the Data Acquisition System and the acoustic navigation. The support vessel will be used primarily to operate an acoustic doppler current profiler. These current data are transmitted via radio between the two ships.

As the cable is being layed, two different navigational systems will be used. A surface electronic range range navigation system will guide both the cable ship and the support vessel on the surface. Underwater, a long-based acoustic navigation system will be used to primarily follow transponders attached to the cable suspension, but to also occasionally follow a manned submersible checking the layed cable.

The PISCES V submersible will check the location of the finally layed cable (through the long-based navigation system), visually look for suspensions or other improper bottom cable configurations and measure tensions in the bottom layed cable. The PISCES V is not an active part of the cable laying process but rather a final check on the success/failure of the cable laying operation. Data from the PISCES V will not be fed back into the control system during the cable lay.




FIGURE 7-11

Ships and Components of the HDWC At-Sea Test

PART 8

BASIC DESIGN CRITERIA REFERENCES

Environmental Factors

Noda, Edward K. and Associates. 1986. Environmental Design Criteria for Cable Deployment Operations in the Alenuihaha Channel.

Pacific Weather, Inc. 1986. Wind Characteristics and General Relationship Between Trade Wind Speeds and Wave Heights in the Alenuihaha Channel.

University of Hawaii, Hawaii Institute of Geophysics. 1983. At-Sea Route Surveys.

Route Factors

DHM Planners, Inc. 1985. Overland Transmission Corridor Study: Hawaii, Maui, Oahu.

DHM Planners, Inc. 1988. Overland Transmission Line Corridor Study: Puna to Kohala, Island of Hawaii.

Makai Ocean Engineering, Inc., Edward K. Noda and Associates and University of Hawaii Institute of Geophysics. 1986. Bottom Roughness Survey of the Alenuihaha Channel.

Makai Ocean Engineering, Inc. and Scripps Institution of Oceanography. 1987. Second Bottom Roughness Survey.

Seafloor Surveys International, Inc. 1987. Side-Scan Sonar and Swath Bathymetry Mapping Survey of the Preferred Cable Route from Maui to Oahu, Hawaii.

Electrical Grid System

Parsons Hawaii, 1985. System Feasibility Criteria.

Power Technologies, Inc. 1984. System Studies.

Power Technologies, Inc. 1986. Phase II-B System Studies.

Power Technologies, Inc. 1987. Phase II-C System Studies.

Cable Subsystem

Pirelli Cable Corporation. 1985. Cable Design Parametric Study.

Pirelli Cable Corporation. 1989. Cable Laboratory Test Program Report.

Cable Vessel Subsystem

Hawaiian Dredging and Construction Company, EG&G and Makai Ocean Engineering. 1984. System Analysis and Parametric Studies.

Hawaiian Dredging and Construction Company. 1986. Cable Vessel Subsystem Feasibility Criteria.

Cable Handling Equipment Subsystem

Hawaiian Dredging and Construction Company, EG&G and Makai Ocean Engineering. 1984. System Analysis and Parametric Studies.

Hawaiian Dredging and Construction Company. 1986. Cable Handling Equipment Subsystem Feasibility Criteria.

Western Gear Machinery Co. 1986. Cable Handling Equipment Concept Study.

At-Sea Test

Makai Ocean Engineering, Inc. and Edward K. Noda and Associates. 1988. Cable Laying Control and Data Acquisition Systems: Final Design Report.